


Taupunkt-Tabelle



Taupunkttafel

Rel. Luftfeuchtigkeit 50...100 %

Lufttemperatur 0...10 °C

50 *)	-9.2	-8.2	-7.3	-6.4	-5.5	-4.5	-3.6	-2.7	-1.8	-0.9	0	50
	-8.9	-8	-7.1	-6.1	-5.2	-4.3	-3.4	-2.4	-1.5	-0.6	0.3	
	-8.7	-7.7	-6.8	-5.9	-5	-4	-3.1	-2.2	-1.2	-0.3	0.6	
	-8.4	-7.5	-6.6	-5.6	-4.7	-3.8	-2.8	-1.9	-1	0	0.9	
	-8.2	-7.3	-6.3	-5.4	-4.5	-3.5	-2.6	-1.7	-0.7	0.2	1.1	
55	-7.9	-7	-6.1	-5.1	-4.2	-3.3	-2.3	-1.4	-0.5	0.5	1.4	55
	-7.7	-6.8	-5.8	-4.9	-4	-3	-2.1	-1.2	-0.2	0.7	1.6	
	-7.5	-6.5	-5.6	-4.7	-3.7	-2.8	-1.9	-0.9	0	0.9	1.9	
	-7.3	-6.3	-5.4	-4.4	-3.5	-2.6	-1.6	-0.7	0.3	1.2	2.1	
	-7	-6.1	-5.2	-4.2	-3.3	-2.3	-1.4	-0.5	0.5	1.4	2.4	
60	-6.8	-5.9	-4.9	-4	-3.1	-2.1	-1.2	-0.2	0.7	1.7	2.6	60
	-6.6	-5.7	-4.7	-3.8	-2.8	-1.9	-0.9	0	0.9	1.9	2.8	
	-6.4	-5.5	-4.5	-3.6	-2.6	-1.7	-0.7	0.2	1.2	2.1	3.1	
	-6.2	-5.2	-4.3	-3.3	-2.4	-1.4	-0.5	0.4	1.4	2.3	3.3	
	-6	-5	-4.1	-3.1	-2.2	-1.2	-0.3	0.7	1.6	2.6	3.5	
65	-5.8	-4.8	-3.9	-2.9	-2	-1	0	0.9	1.8	2.8	3.7	65
	-5.6	-4.6	-3.7	-2.7	-1.8	-0.8	0.1	1.1	2	3	3.9	
	-5.4	-4.4	-3.5	-2.5	-1.6	-0.6	0.3	1.3	2.3	3.2	4.2	
	-5.2	-4.2	-3.3	-2.3	-1.4	-0.4	0.6	1.5	2.5	3.4	4.4	
	-5	-4	-3.1	-2.1	-1.2	-0.2	0.8	1.7	2.7	3.6	4.6	
70	-4.8	-3.8	-2.9	-1.9	-1	0	1	1.9	2.9	3.8	4.8	70
	-4.6	-3.7	-2.7	-1.7	-0.8	0.2	1.1	2.1	3.1	4	5	
	-4.4	-3.5	-2.5	-1.5	-0.6	0.4	1.3	2.3	3.3	4.2	5.2	
	-4.3	-3.3	-2.3	-1.4	-0.4	0.6	1.5	2.5	3.5	4.4	5.4	
	-4.1	-3.1	-2.1	-1.2	-0.2	0.8	1.7	2.7	3.7	4.6	5.6	
75	-3.9	-2.9	-2	-1	0	0.9	1.9	2.9	3.8	4.8	5.8	75
	-3.7	-2.7	-1.8	-0.8	0.2	1.1	2.1	3.1	4	5	6	
	-3.5	-2.6	-1.6	-0.6	0.3	1.3	2.3	3.3	4.2	5.2	6.2	
	-3.4	-2.4	-1.4	-0.5	0.5	1.5	2.5	3.4	4.4	5.4	6.3	
	-3.2	-2.2	-1.3	-0.3	0.7	1.7	2.6	3.6	4.6	5.6	6.5	
80	-3	-2.1	-1.1	-0.1	0.9	1.8	2.8	3.8	4.8	5.7	6.7	80
	-2.9	-1.9	-0.9	0	1	2	3	4	4.9	5.9	6.9	
	-2.7	-1.7	-0.7	0.2	1.2	2.2	3.2	4.1	5.1	6.1	7.1	
	-2.5	-1.6	-0.6	0.4	1.4	2.4	3.3	4.3	5.3	6.3	7.2	
	-2.4	-1.4	-0.4	0.6	1.5	2.5	3.5	4.5	5.5	6.4	7.4	
85	-2.2	-1.2	-0.3	0.7	1.7	2.7	3.7	4.7	5.6	6.6	7.6	85
	-2.1	-1.1	0	0.9	1.9	2.9	3.9	4.8	5.8	6.8	7.8	
	-1.9	-0.9	0	1.1	2	3	4	5	6	7	7.9	
	-1.7	-0.8	0.2	1.2	2.2	3.2	4.2	5.2	6.1	7.1	8.1	
	-1.6	-0.6	0.4	1.4	2.4	3.3	4.3	5.3	6.3	7.3	8.3	
90	-1.4	-0.5	0.5	1.5	2.5	3.5	4.5	5.5	6.5	7.4	8.4	90
	-1.3	-0.3	0.7	1.7	2.7	3.7	4.6	5.6	6.6	7.6	8.6	
	-1.1	-0.2	0.8	1.8	2.8	3.8	4.8	5.8	6.8	7.8	8.8	
	-1	0	1	2	3	4	5	5.9	6.9	7.9	8.9	
	-0.8	0.1	1.1	2.1	3.1	4.1	5.1	6.1	7.1	8.1	9.1	
95	-0.7	0.3	1.3	2.3	3.3	4.3	5.3	6.3	7.2	8.2	9.2	95
	-0.6	0.4	1.4	2.4	3.4	4.4	5.4	6.4	7.4	8.4	9.4	
	-0.4	0.6	1.6	2.6	3.6	4.6	5.6	6.6	7.6	8.5	9.5	
	-0.3	0.7	1.7	2.7	3.7	4.7	5.7	6.7	7.7	8.7	9.7	
	-0.1	0.9	1.9	2.9	3.9	4.9	5.9	6.9	7.9	8.9	9.9	
100	0	1	2	3	4	5	6	7	8	9	10	100
	0	1	2	3	4	5	6	7	8	9	10	

Lufttemperatur 0...10 °C

*) Für relative Luftfeuchtigkeiten unter 50 % dürfen die für 50 % angegebenen Taupunkte angenommen werden.

Taupunkttafel

Rel. Luftfeuchtigkeit 50...100 %

Lufttemperatur 10...20 °C

50 *)	0	1	1.9	2.8	3.8	4.7	5.6	6.5	7.4	8.4	9.3	50
	0.3	1.3	2.2	3.1	4	5	5.9	6.8	7.7	8.6	9.6	
	0.6	1.5	2.5	3.4	4.3	5.2	6.2	7.1	8	8.9	9.9	
	0.9	1.8	2.7	3.7	4.6	5.5	6.4	7.4	8.3	9.2	10.1	
	1.1	2.1	3	3.9	4.8	5.8	6.7	7.6	8.6	9.5	10.4	
55	1.4	2.3	3.2	4.2	5.1	6	7	7.9	8.8	9.8	10.7	55
	1.6	2.6	3.5	4.4	5.4	6.3	7.2	8.2	9.1	10	11	
	1.9	2.8	3.8	4.7	5.6	6.6	7.5	8.4	9.4	10.3	11.2	
	2.1	3.1	4	4.9	5.9	6.8	7.7	8.7	9.6	10.6	11.5	
	2.4	3.3	4.2	5.2	6.1	7.1	8	8.9	9.9	10.8	11.7	
60	2.6	3.5	4.5	5.4	6.4	7.3	8.2	9.2	10.1	11.1	12	60
	2.8	3.8	4.7	5.7	6.6	7.5	8.5	9.4	10.4	11.3	12.3	
	3.1	4	5	5.9	6.8	7.8	8.7	9.7	10.6	11.6	12.5	
	3.3	4.2	5.2	6.1	7.1	8	9	9.9	10.9	11.8	12.7	
	3.5	4.5	5.4	6.4	7.3	8.3	9.2	10.1	11.1	12	13	
65	3.7	4.7	5.6	6.6	7.5	8.5	9.4	10.4	11.3	12.3	13.2	65
	3.9	4.9	5.9	6.8	7.8	8.7	9.7	10.6	11.6	12.5	13.5	
	4.2	5.1	6.1	7	8	8.9	9.9	10.8	11.8	12.7	13.7	
	4.4	5.3	6.3	7.2	8.2	9.1	10.1	11.1	12	13	13.9	
	4.6	5.5	6.5	7.5	8.4	9.4	10.3	11.3	12.2	13.2	14.1	
70	4.8	5.7	6.7	7.7	8.6	9.6	10.5	11.5	12.5	13.4	14.4	70
	5	6	6.9	7.9	8.8	9.8	10.7	11.7	12.7	13.6	14.6	
	5.2	6.2	7.1	8.1	9	10	11	11.9	12.9	13.8	14.8	
	5.4	6.4	7.3	8.3	9.2	10.2	11.2	12.1	13.1	14.1	15	
	5.6	6.5	7.5	8.5	9.4	10.4	11.4	12.3	13.3	14.3	15.2	
75	5.8	6.7	7.7	8.7	9.6	10.6	11.6	12.5	13.5	14.5	15.4	75
	6	6.9	7.9	8.9	9.8	10.8	11.8	12.7	13.7	14.7	15.6	
	6.2	7.1	8.1	9.1	10	11	12	12.9	13.9	14.9	15.8	
	6.3	7.3	8.3	9.3	10.2	11.2	12.2	13.1	14.1	15.1	16	
	6.5	7.5	8.5	9.4	10.4	11.4	12.4	13.3	14.3	15.3	16.2	
80	6.7	7.7	8.7	9.6	10.6	11.6	12.6	13.5	14.5	15.5	16.4	80
	6.9	7.9	8.8	9.8	10.8	11.8	12.7	13.7	14.7	15.7	16.6	
	7.1	8	9	10	11	12	12.9	13.9	14.9	15.9	16.8	
	7.2	8.2	9.2	10.2	11.2	12.1	13.1	14.1	15.1	16	17	
	7.4	8.4	9.4	10.4	11.3	12.3	13.3	14.3	15.3	16.2	17.2	
85	7.6	8.6	9.6	10.5	11.5	12.5	13.5	14.5	15.4	16.4	17.4	85
	7.8	8.8	9.7	10.7	11.7	12.7	13.7	14.6	15.6	16.6	17.6	
	7.9	8.9	9.9	10.9	11.9	12.9	13.8	14.8	15.8	16.8	17.8	
	8.1	9.1	10.1	11.1	12	13	14	15	16	17	18	
	8.3	9.3	10.2	11.2	12.2	13.2	14.2	15.2	16.2	17.1	18.1	
90	8.4	9.4	10.4	11.4	12.4	13.4	14.4	15.3	16.3	17.3	18.3	90
	8.6	9.6	10.6	11.6	12.6	13.5	14.5	15.5	16.5	17.5	18.5	
	8.8	9.8	10.7	11.7	12.7	13.7	14.7	15.7	16.7	17.7	18.7	
	8.9	9.9	10.9	11.9	12.9	13.9	14.9	15.9	16.9	17.8	18.8	
	9.1	10.1	11.1	12.1	13.1	14	15	16	17	18	19	
95	9.2	10.2	11.2	12.2	13.2	14.2	15.2	16.2	17.2	18.2	19.2	95
	9.4	10.4	11.4	12.4	13.4	14.4	15.4	16.4	17.4	18.3	19.3	
	9.5	10.5	11.5	12.5	13.5	14.5	15.5	16.5	17.5	18.5	19.5	
	9.7	10.7	11.7	12.7	13.7	14.7	15.7	16.7	17.7	18.7	19.7	
	9.9	10.8	11.8	12.8	13.8	14.8	15.8	16.8	17.8	18.8	19.8	
100	10	11	12	13	14	15	16	17	18	19	20	100
	10	11	12	13	14	15	16	17	18	19	20	

Lufttemperatur 10...20 °C

*) Für relative Luftfeuchten unter 50 % dürfen die für 50 % angegebenen Taupunkte angenommen werden.

Taupunkttafel

Rel. Luftfeuchtigkeit 50...100 %

Lufttemperatur 20...30 °C

50 *)	9.3	10.2	11.1	12	12.9	13.9	14.8	15.7	16.6	17.5	18.4	50
	9.6	10.5	11.4	12.3	13.2	14.2	15.1	16	16.9	17.8	18.8	
	9.9	10.8	11.7	12.6	13.5	14.5	15.4	16.3	17.2	18.1	19.1	
	10.1	11.1	12	12.9	13.8	14.8	15.7	16.6	17.5	18.5	19.4	
	10.4	11.3	12.3	13.2	14.1	15	16	16.9	17.8	18.8	19.7	
55	10.7	11.6	12.5	13.5	14.4	15.3	16.3	17.2	18.1	19	20	55
	11	11.9	12.8	13.8	14.7	15.6	16.5	17.5	18.4	19.3	20.3	
	11.2	12.2	13.1	14	15	15.9	16.8	17.8	18.7	19.6	20.6	
	11.5	12.4	13.4	14.3	15.2	16.2	17.1	18	19	19.9	20.8	
	11.7	12.7	13.6	14.6	15.5	16.4	17.4	18.3	19.2	20.2	21.1	
60	12	12.9	13.9	14.8	15.8	16.7	17.6	18.6	19.5	20.4	21.4	60
	12.3	13.2	14.1	15.1	16	17	17.9	18.8	19.8	20.7	21.7	
	12.5	13.4	14.4	15.3	16.3	17.2	18.2	19.1	20	21	21.9	
	12.7	13.7	14.6	15.6	16.5	17.5	18.4	19.4	20.3	21.2	22.2	
	13	13.9	14.9	15.8	16.8	17.7	18.7	19.6	20.6	21.5	22.4	
65	13.2	14.2	15.1	16.1	17	18	18.9	19.9	20.8	21.8	22.7	65
	13.5	14.4	15.4	16.3	17.3	18.2	19.2	20.1	21.1	22	23	
	13.7	14.6	15.6	16.5	17.5	18.4	19.4	20.3	21.3	22.2	23.2	
	13.9	14.9	15.8	16.8	17.7	18.7	19.6	20.6	21.5	22.5	23.4	
	14.1	15.1	16.1	17	18	18.9	19.9	20.8	21.8	22.7	23.7	
70	14.4	15.3	16.3	17.2	18.2	19.1	20.1	21.1	22	23	23.9	70
	14.6	15.5	16.5	17.5	18.4	19.4	20.3	21.3	22.2	23.2	24.2	
	14.8	15.8	16.7	17.7	18.6	19.6	20.6	21.5	22.5	23.4	24.4	
	15	16	16.9	17.9	18.9	19.8	20.8	21.7	22.7	23.7	24.6	
	15.2	16.2	17.2	18.1	19.1	20	21	22	22.9	23.9	24.9	
75	15.4	16.4	17.4	18.3	19.3	20.3	21.2	22.2	23.2	24.1	25.1	75
	15.6	16.6	17.6	18.5	19.5	20.5	21.4	22.4	23.4	24.3	25.3	
	15.8	16.8	17.8	18.8	19.7	20.7	21.7	22.6	23.6	24.6	25.5	
	16	17	18	19	19.9	20.9	21.9	22.8	23.8	24.8	25.7	
	16.2	17.2	18.2	19.2	20.1	21.1	22.1	23	24	25	26	
80	16.4	17.4	18.4	19.4	20.3	21.3	22.3	23.3	24.2	25.2	26.2	80
	16.6	17.6	18.6	19.6	20.5	21.5	22.5	23.5	24.4	25.4	26.4	
	16.8	17.8	18.8	19.8	20.7	21.7	22.7	23.7	24.6	25.6	26.6	
	17	18	19	20	20.9	21.9	22.9	23.9	24.8	25.8	26.8	
	17.2	18.2	19.2	20.1	21.1	22.1	23.1	24.1	25	26	27	
85	17.4	18.4	19.4	20.3	21.3	22.3	23.3	24.3	25.2	26.2	27.2	85
	17.6	18.6	19.5	20.5	21.5	22.5	23.5	24.5	25.4	26.4	27.4	
	17.8	18.8	19.7	20.7	21.7	22.7	23.7	24.6	25.6	26.6	27.6	
	18	18.9	19.9	20.9	21.9	22.9	23.9	24.8	25.8	26.8	27.8	
	18.1	19.1	20.1	21.1	22.1	23.1	24	25	26	27	28	
90	18.3	19.3	20.3	21.3	22.3	23.2	24.2	25.2	26.2	27.2	28.2	90
	18.5	19.5	20.5	21.5	22.4	23.4	24.4	25.4	26.4	27.4	28.4	
	18.7	19.6	20.6	21.6	22.6	23.6	24.6	25.6	26.6	27.6	28.6	
	18.8	19.8	20.8	21.8	22.8	23.8	24.8	25.8	26.8	27.8	28.7	
	19	20	21	22	23	24	25	26	26.9	27.9	28.9	
95	19.2	20.2	21.2	22.2	23.1	24.1	25.1	26.1	27.1	28.1	29.1	95
	19.3	20.3	21.3	22.3	23.3	24.3	25.3	26.3	27.3	28.3	29.3	
	19.5	20.5	21.5	22.5	23.5	24.5	25.5	26.5	27.5	28.5	29.5	
	19.7	20.7	21.7	22.7	23.7	24.7	25.7	26.7	27.7	28.7	29.6	
	19.8	20.8	21.8	22.8	23.8	24.8	25.8	26.8	27.8	28.8	29.8	
100	20	21	22	23	24	25	26	27	28	29	30	100
	20	21	22	23	24	25	26	27	28	29	30	

Lufttemperatur 20...30 °C

*) Für relative Luftfeuchten unter 50 % dürfen die für 50 % angegebenen Taupunkte angenommen werden.

Taupunkttafel

Rel. Luftfeuchtigkeit 50...100 %

Lufttemperatur 30...40 °C

50 *)	18.4	19.4	20.3	21.2	22.1	23	23.9	24.8	25.8	26.7	27.6	50
	18.8	19.7	20.6	21.5	22.4	23.3	24.3	25.2	26.1	27	27.9	
	19.1	20	20.9	21.8	22.7	23.7	24.6	25.5	26.4	27.3	28.3	
	19.4	20.3	21.2	22.1	23.1	24	24.9	25.8	26.7	27.7	28.6	
	19.7	20.6	21.5	22.4	23.4	24.3	25.2	26.1	27.1	28	28.9	
55	20	20.9	21.8	22.8	23.7	24.6	25.5	26.5	27.4	28.3	29.2	55
	20.3	21.2	22.1	23	24	24.9	25.8	26.8	27.7	28.6	29.5	
	20.6	21.5	22.4	23.3	24.3	25.2	26.1	27.1	28	28.9	29.8	
	20.8	21.8	22.7	23.6	24.6	25.5	26.4	27.4	28.3	29.2	30.2	
	21.1	22	23	23.9	24.8	25.8	26.7	27.7	28.6	29.5	30.4	
60	21.4	22.3	23.3	24.2	25.1	26.1	27	27.9	28.9	29.8	30.7	60
	21.7	22.6	23.5	24.5	25.4	26.3	27.3	28.2	29.2	30.1	31	
	21.9	22.9	23.8	24.7	25.7	26.6	27.6	28.5	29.4	30.4	31.3	
	22.2	23.1	24.1	25	26	26.9	27.8	28.8	29.7	30.7	31.6	
	22.4	23.4	24.3	25.3	26.2	27.2	28.1	29.1	30	30.9	31.9	
65	22.7	23.6	24.6	25.5	26.5	27.4	28.4	29.3	30.3	31.2	32.2	65
	23	23.9	24.8	25.8	26.7	27.7	28.6	29.6	30.5	31.5	32.4	
	23.2	24.1	25.1	26	27	27.9	28.9	29.8	30.8	31.7	32.7	
	23.4	24.4	25.3	26.3	27.3	28.2	29.2	30.1	31.1	32	33	
	23.7	24.6	25.6	26.5	27.5	28.5	29.4	30.4	31.3	32.3	33.2	
70	23.9	24.9	25.8	26.8	27.7	28.7	29.7	30.6	31.6	32.5	33.5	70
	24.2	25.1	26.1	27	28	28.9	29.9	30.9	31.8	32.8	33.7	
	24.4	25.4	26.3	27.3	28.2	29.2	30.1	31.1	32.1	33	34	
	24.6	25.6	26.5	27.5	28.5	29.4	30.4	31.3	32.3	33.3	34.2	
	24.9	25.8	26.8	27.7	28.7	29.7	30.6	31.6	32.5	33.5	34.5	
75	25.1	26	27	28	28.9	29.9	30.9	31.8	32.8	33.7	34.7	75
	25.3	26.3	27.2	28.2	29.2	30.1	31.1	32.1	33	34	34.9	
	25.5	26.5	27.5	28.4	29.4	30.4	31.3	32.3	33.3	34.2	35.2	
	25.7	26.7	27.7	28.6	29.6	30.6	31.5	32.5	33.5	34.5	35.4	
	26	26.9	27.9	28.9	29.8	30.8	31.8	32.7	33.7	34.7	35.7	
80	26.2	27.1	28.1	29.1	30.1	31	32	33	33.9	34.9	35.9	80
	26.4	27.4	28.3	29.3	30.3	31.2	32.2	33.2	34.2	35.1	36.1	
	26.6	27.6	28.5	29.5	30.5	31.5	32.4	33.4	34.4	35.4	36.3	
	26.8	27.8	28.7	29.7	30.7	31.7	32.6	33.6	34.6	35.6	36.6	
	27	28	29	29.9	30.9	31.9	32.9	33.8	34.8	35.8	36.8	
85	27.2	28.2	29.2	30.1	31.1	32.1	33.1	34.1	35	36	37	85
	27.4	28.4	29.4	30.3	31.3	32.3	33.3	34.3	35.2	36.2	37.2	
	27.6	28.6	29.6	30.5	31.5	32.5	33.5	34.5	35.5	36.4	37.4	
	27.8	28.8	29.8	30.7	31.7	32.7	33.7	34.7	35.7	36.6	37.6	
	28	29	30	30.9	31.9	32.9	33.9	34.9	35.9	36.8	37.8	
90	28.2	29.2	30.1	31.1	32.1	33.1	34.1	35.1	36.1	37.1	38	90
	28.4	29.4	30.3	31.3	32.3	33.3	34.3	35.3	36.3	37.3	38.2	
	28.6	29.5	30.5	31.5	32.5	33.5	34.5	35.5	36.5	37.5	38.4	
	28.7	29.7	30.7	31.7	32.7	33.7	34.7	35.7	36.7	37.7	38.6	
	28.9	29.9	30.9	31.9	32.9	33.9	34.9	35.9	36.9	37.9	38.8	
95	29.1	30.1	31.1	32.1	33.1	34.1	35.1	36.1	37.1	38	39	95
	29.3	30.3	31.3	32.3	33.3	34.3	35.3	36.3	37.2	38.2	39.2	
	29.5	30.5	31.5	32.5	33.5	34.5	35.4	36.4	37.4	38.4	39.4	
	29.6	30.6	31.6	32.6	33.6	34.6	35.6	36.6	37.6	38.6	39.6	
	29.8	30.8	31.8	32.8	33.8	34.8	35.8	36.8	37.8	38.8	39.8	
100	30	31	32	33	34	35	36	37	38	39	40	100
	30	31	32	33	34	35	36	37	38	39	40	

Lufttemperatur 30...40 °C

*) Für relative Luftfeuchten unter 50 % dürfen die für 50 % angegebenen Taupunkte angenommen werden.